

**7. LOWER OWENS RIVER PROJECT  
PUMP STATION REPORT**

## **7. LOWER OWENS RIVER PROJECT PUMP STATION REPORT**

The August 2004 Amended Stipulation and Order in Case No. SICV01-29768, Stipulation Section 1, requires that LADWP submit an annual report to the other MOU Parties that demonstrates compliance with the provision that the Lower Owens River Project (LORP) pump station is limited to a maximum capacity of 50 cfs. Table 28 provides the 2007 pumping rates for the LORP Pump Station. Table 28 data shows that since reaching the Lower Owens River baseflow on February 20, 2007 the pump station flows during the 2006-07 runoff was less than 50 cfs. The current daily average flow at the pump station and all the LORP measuring stations is posted on LADWP's web site, [www.ladwp.com](http://www.ladwp.com).

Table 28 - Lower Owens River Project Pump Station Flows (cfs)

Date	Intake	Black-rock	E/O Goose	Two Culverts	Mazourka	Manzanar	Rein-hackle	LP at NG Rd	Keeler Bridge	PS Above	Pump-back	Release to Delta	Weir Flow to Delta	Avg
2/20/2007		50	41	49	44	47	42	38	44	43	40	3	0	44.2
2/22/2007	56	53	*N/A	48	46	49	*N/A	44	51	47	44	3	0	49.3
2/24/2007	58	60	52	46	50	52	*N/A	48	50	44	41	3	0	51.1
2/26/2007	53	53	*50	41	41	49	44	58	50	50	47	3	0	43.9
2/28/2007	55	53	53	48	40	46	42	41	49	52	49	3	0	47.9
3/5/2007	47	51	51	44	43	44	44	48	51	50	47	3	0	47.3
3/7/2007	52	55	52	44	41	49	N/A	43	53	50	47	3	0	48.8
3/12/2007	46	47	46	49	43	45	42	48	53	53	48	3	2	47.2
3/14/2007	48	45	42	43	45	41	N/A	40	53	50	47	3	0	45.2
3/16/2007	49	48	43	42	47	43	N/A	42	53	51	48	3	0	46.4
3/19/2007	48	47	44	39	47	43	N/A	42	53	53	48	3	2	46.2
3/20/2007	49	49	42	41	41	43	34	46	51	52	48	3	1	44.8
3/21/2007	47	47	45	40	43	43	36	42	47	50	47	3	0	44.0
3/22/2007	50	44	42	39	40	41	31	40	46	47	44	3	0	42.0
3/23/2007	51	48	43	38	38	40	38	41	46	47	44	3	0	43.0
3/24/2007	52	49	46	41	36	39	38	41	44	45	42	3	0	43.1
3/26/2007	52	46	47	43	42	39	41	40	43	44	41	3	0	43.7
3/27/2007	52	51	46	42	41	43	39	40	46	41	38	3	0	44.1
3/28/2007	52	49	48	42	39	41	36	40	48	43	40	3	0	43.8
3/29/2007	52	46	47	41	41	40	37	37	43	42	39	3	0	42.6

