

Dr. Bob Harrington
Inyo County Water Department
135 South Jackson Street
Independence, CA 93526

September 1, 2011

RE: Summary of Hydrologic Monitoring Activities August 2011
Rose Valley, Inyo County, California
Hay Ranch Project Conditional Use Permit #2007-03

Dear Dr. Harrington:

This letter is intended to summarize hydrologic monitoring activities conducted in August 2011 by TEAM Engineering & Management, Inc. (TEAM), related to the Hay Ranch Water Extraction Project and CUP #2007-03.

Background

As outlined in the Hay Ranch Water Extraction Final EIR's Hydrologic Monitoring and Mitigation Plan (HMMP), Phase 1: Monitoring System Setup and Supplemental Data Collection occurred prior to December 25, 2009 at monitoring points throughout Rose Valley. With the initiation of pumping by Coso Operating Company (Coso) on December 25, 2009, the Hay Ranch Water Extraction Project entered into the Phase 2: Startup Monitoring and Reporting period. Phase 3: Model Recalibration and Redefinition of Pumping Rates and Durations occurred from September 2010 to April 2011, with recalibration of the groundwater model by Daniel B. Stephens & Associates (DBS&A) and with redefinition of pumping rates and durations by Inyo County Water Department (ICWD). With the April 1, 2011 issuance of the ICWD's "Addendum to the HMMP for CUP#2007-003/Coso Operating Company, LLC" (2011 ICWD Addendum) the project has entered Phase 4: Ongoing Monitoring, Mitigation and Reporting.

Monitoring and Reporting

During the July 2011 monthly hydrologic data collection event at 30 monitoring locations in the Rose Valley area, static depth-to-water (DTW) measurements, one visual observation of the Little Lake Ranch (LLR) Siphon Well Outflow and four sets of flow rates were collected by TEAM, as summarized in the attached table (Table 1). Data for this monthly field event was collected on August 24 and 25. Pressure transducer data were downloaded from 24 units, including one "BaroTroll" measuring barometric pressure. On August 2, a DTW measurement at LADWP 816 Well was taken by LADWP personnel.

At the Hay Ranch Property, Coso pumped groundwater from two production wells: Hay Ranch North and Hay Ranch South. For the first year of project pumping, from December 25, 2009 to December 24, 2010, a total of approximately 2992 acre feet (AF) of groundwater were extracted from these two wells (821 AF from the Hay Ranch North Well, and 2171 AF from the Hay Ranch South Well).

During the January 1, 2011 to August 25, 2011 period, a total of approximately 2537 AF of groundwater have been extracted from the Hay Ranch property (880 AF from the Hay Ranch North Well, and 1658 AF from the Hay Ranch South Well).

Figure 1 presents the combined amount of groundwater pumped from the Hay Ranch North and South wells (in AF) from December 25, 2009 through August 25, 2011 compared to a hypothetical pumping amount. The total amount of groundwater extracted from the Hay Ranch property from December 25, 2009 to August 25, 2011 was approximately 5604 AF. The hypothetical pumping amount assumes a

pumping rate of approximately 3000 acre-feet per year (AFY) for December 25, 2009 through December 31, 2010 and assumes a pumping rate of approximately 4839 AFY from January 1, 2011 through December 31, 2011. These hypothetical pumping rates represent the maximum allowable pumping amounts for the 2010 and 2011 periods.

Trigger Levels and Maximum Acceptable Drawdowns

In Table 2 of the 2011 ICWD Addendum, drawdown at cessation of pumping trigger levels (Trigger Levels) have been set for specific monitoring wells based on an annual pumping rate of 4839 AFY.

Based on the manual depth to water (DTW) data collected by TEAM on August 24-25, 2011, the Trigger Level for the Little Lake Ranch (LLR) North Well (RV180) has been exceeded. The baseline groundwater elevation (GWE) for LLR North, set by Inyo County Water Department in January 2010, is 3158.88 feet. The GWE at LLR North as measured at 11:30 on August 25 was 3158.87 feet. The Trigger Level for LLR North is 0.00 feet. The LLR North GWE has decreased by 0.01 feet compared to its baseline, exceeding its Trigger Level by 0.01 feet (Table 2). On August 25, the LLR North GWE was 1.29 feet above its Maximum Acceptable Drawdown level. ICWD was notified of this Trigger Level exceedance in a timely manner.

Based on data collected by TEAM during the August 2011 monitoring event, no other Trigger Levels or Maximum Acceptable Drawdowns have been exceeded at Hay Ranch Project monitoring wells which have baselines and trigger levels established.

Operational Notes

At Davis Ranch South Well, the in-well pressure transducer experienced significant upward pressure drift during the previous monitoring period (June-July 2011) that was not confirmed by manual measurements. This was a recurring issue with this transducer. Therefore, a new transducer was installed on August 24, 2011.

At Hay Ranch 2B and 2C, the pressure transducers experienced power instability and were removed from the wells on July 20, 2011. These units are being repaired, and the repaired units will be re-installed.

At Little Lake Ranch, one instance of water management was note worthy. For parts of the July-August 2011 monitoring period, the Dock Well was actively pumped. Temporary groundwater level drawdowns were captured by the in-well pressure transducer at the Dock Well.

Data Transmittal

TEAM posted updates to the "Coso" database on the ICWD web server. New Hay Ranch Project hydrographs in PDF form were uploaded to the ICWD website (www.inyowater.org).

* * * * *

If you have any questions or require additional information, please contact TEAM at your convenience.

Sincerely,

TEAM Engineering & Management, Inc.

Keith Rainville
Staff Geologist

TABLE 1
Field Observations of Rose Valley Hydrologic Monitoring Points
August 24-25, 2011

Project Name:	Hay Ranch Project HMMP	Date: August 24-25, 2011
Location:	Rose Valley, Inyo County	
Observer(s):	K. Rainville	Page: 1 of 1

Well ID	Monitoring Point	Date	Time	DTW (ft)	Flow (cfs)	GWE (ft amsl)	Method	Transducer Log Interval	Notes
RV-10	Dews	08/24/11	15:50	231.36		3755.56	TEAM manual read	NA	
RV-20	LADWP 816	08/02/11	11:23	76.42		3438.64	LADWP manual read	NA	Data provided by LADWP
RV-30	Cal Pumice	08/24/11	10:00	254.95		3250.94	TEAM manual read	Hourly	
RV-40	Dunmovin	08/25/11	9:00	300.81		3247.06	TEAM manual read	NA	
RV-50	Hay Ranch North	08/25/11	12:18	NM	Yes	NM	TEAM manual read	NA	563,510,047 gallons (1729 AF) pumped since 12/25/09
RV-60	Hay Ranch 1A	08/24/11	10:37	201.11		3231.06	TEAM manual read	Hourly	
RV-61	Hay Ranch 1B	08/24/11	10:43	229.21		3202.64	TEAM manual read	Hourly	
RV-62	Hay Ranch 1C	08/24/11	10:49	218.57		3212.93	TEAM manual read	Hourly	
RV-70	Hay Ranch South	08/25/11	12:19	NM	Yes	NM	TEAM manual read	NA	1,262,517,950 gallons (3875 AF) pumped since 12/25/09
RV-80	Hay Ranch 2A	08/24/11	10:57	200.85		3232.15	TEAM manual read	Hourly	
RV-81	Hay Ranch 2B	08/24/11	11:01	228.82		3203.81	TEAM manual read	Hourly	
RV-82	Hay Ranch 2C	08/24/11	11:03	212.21		3219.89	TEAM manual read	Hourly	
RV-90	Coso Jct Ranch	08/24/11	10:18	172.39		3230.74	TEAM manual read	Hourly	
RV-100	Coso Jct Store #1	08/24/11	13:51	145.38		3226.74	TEAM manual read	Hourly	
RV-110	Davis Ranch North Well	08/24/11	14:10	6.48		3886.52	TEAM manual read	Hourly	
RV-111	Davis Ranch South Well	08/24/11	14:27	11.25		3886.75	TEAM manual read	Hourly	
RV-112	Davis Ranch South Flow	08/25/11	15:02	NA	0.01	NA	TEAM manual read	Hourly	
RV-120	Red Hill Well (BLM)	08/24/11	11:23	139.89		3200.94	TEAM manual read	Hourly	
RV-130	G-36	08/24/11	13:35	180.18		3199.84	TEAM manual read	NA	
RV-140	Lego	08/24/11	13:26	222.18		3200.67	TEAM manual read	Hourly	
RV-150	Cinder Road	08/24/11	12:15	190.91		3187.05	TEAM manual read	Hourly	
RV-160	18-28 GTH	08/24/11	13:08	173.89		3188.69	TEAM manual read	Hourly	
RV-170	Fossil Falls Campground	08/24/11	12:00	141.07		3175.70	TEAM manual read	NA	
RV-180	LLR North Well	08/25/11	11:30	40.23		3158.87	TEAM manual read	Hourly	
RV-210	LLR Dock Well	08/25/11	9:40	6.62		3147.52	TEAM manual read	Hourly	
RV-220	LLR Stilling Well (lake surface)	08/25/11	9:54	4.11		3146.93	TEAM manual read	Hourly	
RV-230	LLR Little Lake Outflow	08/25/11	10:37	NA	0.00	NA	TEAM manual read	Hourly	No Flow
RV-240	LLR Coso Springs Flow	08/25/11	10:16	NA	0.34	NA	TEAM manual read	Hourly	
RV-245	LLR North Culvert Flow	08/25/11	11:35	NA	2.17	NA	TEAM manual read	Hourly	
RV-250	LLR Siphon Discharge	08/25/11	10:50	NA	Yes	NA	TEAM visual read	NA	Siphon Well flowing into Pond 2
RV-260	LLR Hotel Well	08/25/11	9:25	1.12		3137.66	TEAM manual read	Hourly	

NM - not measured; NA - not applicable; IO - Inoperative

DTW - Depth to water in feet (ft) below top of casing or other reference point; a negative DTW indicates that the groundwater elevation is above the surveyed reference point

Flow - In cubic feet per second (cfs)

GWE- Groundwater elevation in feet above mean sea level (ft amsl)

TABLE 2
Hay Ranch Project Groundwater Baselines and Trigger Levels
August 2011


Well ID	Monitoring Point	Baseline GWE ¹ (feet amsl)	Recent Date of Measurement	Recent GWE (feet amsl)	Recent GWE Compared to Baseline (feet)	Recent GWE Above Max DD ² (feet)	Trigger Level At Cessation of Pumping ³ (feet)	Recent GWE Compared to Trigger Level (feet)
RV-40	Dunmovin	3252.73	08/25/11	3247.06	-5.67	17.63	23.2	17.53
RV-80	HR 2A	3240.92	08/24/11	3232.15	-8.77	18.83	27.6	18.83
RV-90	Coso Jct Ranch	3230.65	08/24/11	3230.74	0.09	11.79	11.3	11.39
RV-100	Coso Jct Store #1	3227.59	08/24/11	3226.74	-0.85	9.25	9.5	8.65
RV-120	Red Hill Well	3200.66	08/24/11	3200.94	0.28	4.18	1.8	2.08
RV-130	G-36	3198.35	08/24/11	3199.84	1.49	4.89	1.0	2.49
RV-140	Lego	3199.21	08/24/11	3200.67	1.46	3.76	0.0	1.46
RV-150	Cinder Road	3186.92	08/24/11	3187.05	0.13	2.43	0.2	0.33
RV-160	18-28 GTH	3187.67	08/24/11	3188.69	1.02	3.12	0.0	1.02
RV-180	LLR North Well	3158.88	08/25/11	3158.87	-0.01	1.29	0.0	-0.01

1) GWE: Groundwater elevation measured in feet above mean sea level. Baseline GWEs set January 2010 and March 2011 and approved by Inyo County Water Department

2) Max DD: Maximum Acceptable Drawdown from Table 2 of "Addendum to HMMP for CUP#2007-003/Coso Operating Company, LLC"

3) Trigger Level at Cessation of Pumping from Table 2 of "Addendum to HMMP for CUP#2007-003/Coso Operating Company, LLC"

FIGURE 1
HYPOTHETICAL AND ACTUAL HAY RANCH PROJECT PUMPING



Note: Coso Operating Co. initiated Hay Ranch Project pumping on 12/25/09.

The "hypothetical pumping rate" is based on a pumping rate of 3000 AF per year for 12/25/09 to 12/31/10, and 4839 AF per year for 1/1/11 to 12/31/11.